



International Organization for Migration (IOM)
The UN Migration Agency

Date. 16/3/2023

Bid Bulletin No 4

Supply, delivery and installation of Modular buildings (containers) and Accompanying Structures at First Reception Center “Pournara” in Cyprus

ITB 2023.CYP.01.MH

Question 1:

- 1. In order for the minimum internal height to be 2.40m with a minimum slope 2% of the roof, the external height of the container shall be 2.75m. Is this acceptable?*
- 2. Shall we submit the technical offer in English, or is it allowed to submit it in Greek, since the specifications are also in Greek?*
- 3. Section 4, Eligibility Criteria: Shall we declare the Agent that will represent us in Cyprus for the maintenance, repair and spare parts with the submission of our offer? If yes, what kind of document shall we submit with our offer (i.e. cooperation agreement, declaration etc.).*

Answer 1:

1. We accept the external height of the container to be 2.75m. Generally, an increase of up to 5cm in container's frame dimensions is accepted, however any decrease in container dimensions will not be accepted."
2. According to Section 3, Article 11, "All bids, information, documents and correspondence exchanged between IOM and the bidders in relation to this bid process shall be in English language"
3. Yes. Proof documentation of the established Agent, in the form of an Agreement is required.